

DECLARATION OF PERFORMANCE
No. 13-03

1. Unique identification code of the product-type:

346-300, 346-302, 346-301

2. Number of series or batch type, or any other element enabling identification of the building product, in accordance with article 11, paragraph 4:

- Coil, small coil and sheet
- In PIGMENTO[®], all colours
- Thickness between 0.7 mm and 1.5 mm
- All widths

3. Intended use of the building product, in accordance with the relevant applicable harmonised technical specification, as intended by the manufacturer

Self-supporting metal sheets for roofing, external and internal cladding, and partition walls.

4. Name, business name or registered trademark and contact address of the manufacturer, in accordance with article 11, paragraph 5 and address of the producer:

Umicore Building Products France S.A.S.
Les Mercuriales - Tour du Ponant
40 rue Jean Jaurès
FR-93176 Bagnolet Cedex - France

5. Where applicable, Name and address of the authorised representative, in accordance with article 12 § 2

Non applicable

6. Systems of Assessment and Verification of Constancy of Performance

3 for fire

4 for other characteristics

7. Notified body (case of hEN)

The LNE (notified body n° NB 0071) conducted Reaction to fire testing in accordance with system 3 and issued test reports n° H061009 CEMATE/14 and n° H061009 CEMATE/19 and Reaction to Fire classification report n° H061009 CEMATE/4

8. Declaration of performance of a product for which a European Technical Assessment has been issued:

Non applicable

9. Declared performance

All of the characteristics listed in the table below refer to harmonised standard hEN 14782, and in particular to its appendix ZA.

Key characteristics	Performance	Harmonised Technical Specifications
Mechanical resistance (concentrated load 1.2 kN)	NPD	hEN 14782
Water permeability	Satisfactory ^(a)	hEN 14782
Dimensional variation	$22 \times 10^{-6} \text{ K}^{-1}$	hEN 14782
Release of regulated hazardous substances	Satisfactory ^{(a)(b)}	
Reaction to Fire	A2-s1, d0	LNE Report n° H061009 CEMATE/4
External roof fire	Satisfactory	Decision 2000/553/CE
Durability	Zn	hEN 14782
<p>(a) Concerns performance of the product alone. (b) The sides in contact with internal air must not release regulated hazardous substances exceeding the authorised maximum levels specified in European or national regulations. European test methods are currently being developed. An informative database on European and national measures concerning regulated substances can be consulted on the EUROPA Construction website (accessible at:</p>		

http://ec.europa.eu/enterprise/construction/internal/dangsub/dangmain_en.htm

10. The performance of the product identified in points 1 and 2 complies with the performance declared in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for the manufacturer and in his name by

Pierre VAN DE BRUAENE, President

Bagnolet, 1st July 2013

A handwritten signature in black ink, appearing to read 'Pierre Van de Bruaene', enclosed within a large, loopy oval stroke.